



**UPON DEVICE ACTIVATION "EXIT" SIGN 02-10105**



**DESCRIPTION**

The purpose of the System Discharge Sign is to explain the presence of an alarm in the event of an HFC-227ea System discharge. The sign is 9" x 6" x 1/16" (229 x 152 x 1.6mm) and is constructed of white plastic with black lettering. The System Discharge Sign is located next to or under an audible or visual alarm inside of the protected space. This sign, together with the alarm device, will alert personnel when HFC-227ea agent has been discharged and allow them to take appropriate action.


**SYSTEM ABORT "PUSH AND HOLD" SIGN 02-10106**



**DESCRIPTION**

The purpose of this System Abort Sign is to identify the presence of the HFC-227ea System Abort Station. The sign is 4" x 2.25" x 1/16" (102 x 57 x 1.6mm) and is constructed of red plastic with white lettering. The System Abort Station is designed to provide a manual means by which the HFC-227ea system actuation circuit may be interrupted. The System Abort Sign should be located next to each HFC-227ea Abort Station for quick positive identification


**SYSTEM "MAIN / RESERVE" SIGN 02-10107**



**DESCRIPTION**

The purpose of Main/Reserve Sign is to identify the presence of the HFC-227ea Main/Reserve Switch Station. The sign is 4" x 2.25" x 1/16" (102 x 57 x 1.6mm) and is constructed of red plastic with white lettering. The Main/Reserve Sign should be located under the Main/Reserve Switch for positive identification. A Main/Reserve Switch is used with systems that incorporate main and reserve (back up) HFC-227ea Agent storage.

**RELEASE PENDING SIGN 02-10268**



**DESCRIPTION**

The purpose of the Release Pending Sign is to explain the presence of an alarm in the event of an impending HFC-227ea System discharge. The sign is 7" x 4.25" x 1/16" (178 x 108 x 1.6mm) and is constructed of red plastic with white lettering. The Release Pending Sign is located next to an audible or visual alarm inside of the protected space. This sign, together with the alarm device, will alert personnel of a forthcoming HFC-227ea Agent discharge and allow them to take appropriate action.