



APPROVED

Certificate of Compliance

FIXED EXTINGUISHING SYSTEMS, CLEAN AGENT FIRE EXTINGUISHING SYSTEMS

This certificate is issued for the following product:

System Designation:	Fike ProInert™ Fire Extinguishing Systems
System Type:	Engineered Systems
Agent Identification:	ProInert™
Minimum and Maximum Agent Storage Temperatures:	-4°F to 120°F (-20°C to 49°C)
Minimum Design Concentrations for Hazard Class:	Class A – 34.2% Class B – 43.6%
Design, Installation, Operation, and Maintenance Manual:	Design, Installation and Maintenance Manual for ProInert™ Fire Extinguishing System, P/N 06-371, Rev. 2, December 2008.

Approved for: FIKE CORPORATION
 704 SOUTH 10TH STREET
 BLUE SPRINGS, MO 64015
 UNITED STATES

FM Approvals confirms that the products above have been found to comply with the following standards:

UL 2127 – Standard for Inert Gas Clean Agent Extinguishing System Units

Project Identifier: 3025843

Date of Approval: August 3, 2009

Richard B. Dunne
 Manager – Hydraulics Group, FM Approvals

8/3/09

Date



Member of the FM Global Group